LINKWARE
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: 6TH FLOOR/CABLE A/001

Test Summary: PASS

Date / Time: 27/09/2006 13:43:50
Headroom: 2.04 dB (Loss)
Test Limit: General Fiber Optic
Cable Type: SYSTIMAX LazrSPEED (50)

Operator: JEL CLARK
Software Version: 1.2200
Limits Version: 1.0200

Model: DTX-1800
Main S/N: 8824049
Remote S/N: 8824048
Main Adapter: DTX-MFM
Remote Adapter: DTX-MFM

n = 1.5000
Number of Adapters: 2
Number of Splices: 0
Patch Type: SYSTIMAX LazrSPEED (50)
Patch Length1 (m): 2.0
Patch Length2 (m): 2.0
Patch Length3 (m): 1.0

Propagation Delay (ns)	337
Length (m), Limit 1000.0	67.4 PASS

Direction	Remote->Main	Remote->Main
Wavelength (nm)	850	1300
Result	PASS	PASS
Loss (dB)	0.01	0.00
Loss Limit (dB)	4.50	2.20
Loss Margin (dB)	4.49	2.20
Reference (dBm)	-23.35	-22.83

27/09/2006 13:13:10
Method A

Direction	Main->Remote	Main->Remote
Wavelength (nm)	850	1300
Result	PASS	PASS
Loss (dB)	0.24	0.16
Loss Limit (dB)	4.50	2.20
Loss Margin (dB)	4.26	2.04
Reference (dBm)	-22.94	-23.09

27/09/2006 13:13:10
Method A

Near End Adapter S/N:	8814015
Calibration Date:	20/02/2006 15:21:27
Far End Adapter S/N:	8814013
Calibration Date:	20/02/2006 15:34:05